

**GDX-350 Transmitter Part Number Configurator**

Part number format 56XY-3BCD

Base Unit Type	Model Type	Sensor	Option
<b>X &amp; Y</b>	3 = GDX-350	<b>B &amp; C</b>	<b>D</b>
00 = 3-wire		01 = CO	1 = 4-20 mA
01 = 2-wire		02 = H2S	2 = 4-20 w/ relays + Modbus RTU
02 = wireless		03 = O2	3 = 4-20 output + arctic
		04 = NO2	4 = 4-20 w/ relays + Modbus RTU + arctic
		05 = NH3	6 = Single remote sensor input w/out relays
		06 = SO2	7 = Single remote sensor input w/relays
		07 = PH3	8 = 900 Mhz
		08 = Cl2	9 = 2.4 GHz
		09 = ClO2	
		10 = CO/H2 null	
		11 = H2	
		20 = CH4 0-100% LEL (CAT), 3-wire only	
		21 = CH4 0-100% LEL (IR), 3-wire only	
		22 = CO2 (IR), 3-wire only	
		23 = C3H8 0-100% LEL (IR), 3-wire only	